



Fire Safety ForceField® FireGuard® for Fabrics

For various reasons, including (i) the very different circumstances that may exist from one fire to another, (ii) the differences between conditions in an actual fire and laboratory conditions in which testing is conducted, and (iii) the inherent variability of fire tests, certifying/labeling ForceField® FireGuard® (FFFG) for use in specific fabric assemblies/systems does not mean that the same application of FFFG will necessarily provide an equivalent protection or the same result in an actual fire or in a new laboratory test. Furthermore, FFFG is to be used only as a component of complete fire retardation systems. It will only contribute to slowing and stopping fire spread on the fabric to which it has been applied and will not, by itself, prevent a fire from starting or continuing. The extent to which FFFG retards or prevents flame spread of a particular fire will depend, among other things, on (i) the amount of FFFG applied, (ii) the conditions and performance of the other elements of the assembly or system incorporating FFFG, and (iii) the conditions of the actual fire itself. FFFG will not make a fire any less dangerous to persons or property. SII cannot guarantee that loss or injury will not be suffered by persons or property. It is the sole responsibility of the applicator to ensure that FFFG has been applied in accordance with the application directions.